



CITY OF HIALEAH BUILDING DEPARTMENT COMMERCIAL ELECTRICAL SERVICE PERMIT

Please also submit the following

- Service Riser Diagram,
- Panel Schedule(s),
- Load Calculations,
- Fault Current Calculation / AIC Ratings of distribution equipment required. NEC 110.9 and 110.10, FBC 106.3.5
- The application must be submitted by a properly licensed contractor. The plans cannot be processed until the application is filled out and signed by a contractor.
- The notarized signature of the person (other than a Registered Architect or Engineer) preparing these drawings is required.
- Electrical systems over 240 volts nominal or with an aggregate service capacity greater than 600 amperes for residential, or 800 amperes for commercial, must be designed by a professional engineer. FS 471.003(2)(h)2.a.
- Florida Statutes require Seal, Date, Signature and Title Block (identify discipline) of a Florida Registered Engineer or Architect. FS 471, FS 481
- Drawings must be to a minimum $\frac{1}{4}$ " scale. Miami-Dade County Code Chapter 8-10(a)(ii).
- Electrical room plan must be drawn to minimum $\frac{1}{2}$ " scale. Miami-Dade Co. Code Chapter 8-10(a)(ii).