

ADDENDUM NO. 2

**CITY OF HIALEAH
INSTALLATION OF WATER MAIN, SANITARY SEWER, FORCE MAIN, SANITARY LIFT STATION
AND FIBER OPTIC CONDUIT SR 916 (NW 138TH STREET / W 84TH STREET)
PROJECT 1063 & 1064**


2008/09-9500-00-058

AUGUST 5, 2009

TO ALL CONCERNED

The original Contract Documents, for the Project entitled CITY OF HIALEAH – INSTALLATION OF WATER MAIN, SANITARY SEWER, FORCE MAIN, SANITARY LIFT STATION AND FIBER OPTIC CONDUIT SR 916 (NW 138TH STREET / W 84TH STREET) PROJECT 1063 & 1064, are hereby amended as noted in this **Addendum No. 2**.

This **Addendum No. 2** consists of 3 Typed Page, 1 ARF, and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: August 5, 2009
Michael Flores – Purchasing Director

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 2** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah at (305) 883-5871 and submitted with sealed bids.

Questions and Answers:

- Q1. Item 102-1 (proposal pages 1F & 1L) requires for bidders to include the costs of uniformed police officer under this item. Will the City reimburse the contractor for these costs (officer)? Is this is not an option, can you provide a separate proposal item for a police officer with a designated number of hours in order for all bidders to be able to bid on the same total number of hours?
- A1. Contractor shall include the cost of providing off-duty policemen for maintenance of traffic for work at intersections along NW 138th Street. This cost shall be included in the pay item for Maintenance of Traffic (Pay Item 102-1). Please provide for 4 full days of having (2) Police Officers maintaining traffic.
- Q2. What is the amount of time to complete the project? And are there liquidated damages on this project?
- A2. Completion time will be 180 days from notice to proceed. A liquidated damage is \$500 per day.
- Q3. Is there a form for the Bid Bond for the project (2008/9-9500-00-058) or we can submit ours? If there is any, what should be the percentage?
- A3. You may submit your own form. Bid bond 5%.
- Q4. What are the liquidated damages for this project? What is the time to complete? None of these sections are included in the General Conditions or in the Technical Special Provision book.
- A4. See answer to question number 2 above.
- Q5. Length of Warranty Required?
- A5. One year from final acceptance date.

ADDENDUM NO. 2

**CITY OF HIALEAH
INSTALLATION OF WATER MAIN, SANITARY SEWER, FORCE MAIN, SANITARY LIFT STATION
AND FIBER OPTIC CONDUIT SR 916 (NW 138TH STREET / W 84TH STREET)
PROJECT 1063 & 1064**

2008/09-9500-00-058

AUGUST 5, 2009

- Q6. Bid bond = 5%? Performance and Labor = 100%?
A6. Yes. AIA form acceptable.
- Q7. After we placing Superpave Asphaltic Concrete surface course, we have to striping the road (Temporary and Final Striping) we do not have pay item for this. Can you clarify? And please give us the quantities?
A7. Temporary striping costs shall be included in the cost for Maintenance of Traffic, pay item 102-1. Quantities for this are provided in the maintenance of traffic sheets of the plans. Final Striping costs shall be averaged into cost per lineal foot of pipeline installation, and shall match existing striping scheme.
- Q8. What is the % of the bid bond, and legal aspect of this contract?
A8. 5%. We don't understand the rest of the question.
- Q9. We do not have any pay item, to include the traffic loops that we have to restored after the water, sewer and force main installation. Can you please clarify?
A9. Please incorporate the cost of restoring traffic loops into the cost of the watermain pipeline installation. The cost per lineal foot of installing the watermain will average in the cost of furnishing and installing traffic loops at the intersection of NW 138th St and NW 57th Ave.
- Q10. We are soliciting respectfully postpone the bid due date at least 5 days after the bid due date 08-11-2009. This is to get enough time to prepare a accurate and responsible bid for the best interest of the City of Hialeah?
A10. No.
- Q11. What are the required thicknesses for the asphalt and lime rock for the trench restoration.
A11. Since this is temporary until the roadway is completed to match existing.
- Q12. What material do you want to use for the articulated concrete block when it pertains to the cables that will anchor the system. The supplier is telling me there are several different options.
A12. The cable for anchoring must be stainless steel cables.
- Q13. Can the work be performed at night? What would the hours be?
A13. No work at night allowed.
- Q14. What governing agency is responsible for the work being performed on the river in relation to permitting.
A14. Dade County canal.
- Q15. Who will the contractor ne required to pull permits with, are there any permit fees for the City of Hialeah.
A15. Permit fees for the City will be waived. We have the MDDERM permits for water and are awaiting the MDDERM permit for sewers.

CITY OF HIALEAH
INSTALLATION OF WATER MAIN, SANITARY SEWER, FORCE MAIN, SANITARY LIFT STATION
AND FIBER OPTIC CONDUIT SR 916 (NW 138TH STREET / W 84TH STREET)
PROJECT 1063 & 1064

2008/09-9500-00-058

AUGUST 5, 2009

Q16. Can the excavated material be used for bedding for the watermain.

A16. No spoils placed on the trench it has to be new material.

Q17. Will the city provide a yard for storage.

A17. No.

Q18. Towards the west end of the project there are some grassy areas, will a city accept seeding and mulching or will they require sod.

A18. Sodding is required for grass area restoration to provide for nicer aesthetics for surrounding businesses.

Q19. Is this a FDOT Roadway? Will we have to pull a permit with FDOT?

A19. City will secure permit.

NO MORE QUESTIONS WILL BE ANSWERED.

ADDENDUM No. 2 – PAGE 3 OF 3

END OF ADDENDUM No. 2

ADDENDUM RECEIPT FORM

CITY OF HIALEAH

**INSTALLATION OF WATER MAIN, SANITARY SEWER, FORCE MAIN, SANITARY LIFT STATION AND
FIBER OPTIC CONDUIT SR 916 (NW 138TH STREET / W 84TH STREET)
PROJECT 1063 & 1064**

2008/09-9500-00-058

AUGUST 5, 2009

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____ **FAX NO.** _____

CONTACT NAME _____ **SIGNATURE** _____

**THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND
DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY of HIALEAH @
(305) 883-5871**

<u>ADDENDUM</u>	<u>SIGNATURE</u>	<u>DATE</u>
<u>2</u>	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____