

**CITY OF HIALEAH  
PALM CENTER PARKING GARAGE  
265 PALM AVENUE  
HIALEAH, FLORIDA**


**June 18, 2010**

TO ALL CONCERNED

The original Contract Documents for the Project entitled: **CITY OF HIALEAH – PALM CENTER PARKING GARAGE – STRUCTURAL PILES, BID NO. 2009/10-3230-00-085** is amended as noted in this Addendum No. 2.

This Addendum No. 2 consists of 1 Typed Page, 0 Sketches 1 Attachment and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:



Date: June 18, 2010

Oniel E. Toledo – Capital Project Manager  
Construction & Maintenance

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 2** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah @ (305) 687-2642 and submitted with sealed bids.

ATTACHMENTS:

**ATT-1 E-MAIL FROM: BERKEL & COMPANY CONTRACTORS (dated 06/18/2010)**

**ANSWER TO: BERKEL & COMPANY CONTRACTORS - e-mail dated 06-18-10**

1. Contractor must provide one (1) compaction test and one (1) tension test. The City of Hialeah will provide the testing company that will monitor the pile load test.

**STRUCTURAL PILES, BID NO. 2009/10-3230-00-085**

**PAGE 1 OF 1  
END OF ADDENDUM No. 2**

**ADDENDUM RECEIPT FORM**

**CITY OF HIALEAH  
PALM CENTER PARKING GARAGE  
STRUCTURAL PILES**

**CONTRACTOR'S NAME** \_\_\_\_\_

**ADDRESS** \_\_\_\_\_

**PHONE NO.** \_\_\_\_\_ **FAX NO.** \_\_\_\_\_

**CONTACT NAME** \_\_\_\_\_ **SIGNATURE** \_\_\_\_\_

**THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY OF HIALEAH @ (305) 687-2642**

**ADDENDUM**

**SIGNATURE**

**DATE**

\_\_\_\_\_  
2

**ARF**

**Toledo, Oniel**

**From:** Stacey Rock [srock@berkelapg.com]  
**Sent:** Friday, June 18, 2010 9:42 AM  
**To:** CLopez@hialeahfl.gov  
**Cc:** Toledo, Oniel  
**Subject:** Milander / Palm Center

Hello Carlos:

Good Morning – I have a question on both projects, if you could please review send answer as soon as possible...

(RE: **MILANDER**) On the summary of work contained in Addendum No. 1, Item # 4, regarding test piles: Please confirm the type and quantity of test piles required. Please note that per the Florida Building Code a 35 ton design load does not require a test pile.

(RE: **PALM CENTER**) On the summary of work contained in Addendum No. 1, Item # 4, regarding test piles: Please confirm the type and quantity of test piles required.

***Please call if you have any questions.***

*Thank You,  
Stacey Rock  
Administration - SF Office*

*Berkel & Company Contractors, Inc.  
3702 Rogers Industrial Park Road  
Okahumpka, FL. 34762*

*Ph: 352-365-4308  
Fax: 352-365-4360  
Email: srock@berkelapg.com*



ATT-1