

**CITY OF HIALEAH
PALM CENTER PARKING GARAGE
265 PALM AVENUE
HIALEAH, FLORIDA**


June 18, 2010

TO ALL CONCERNED

The original Contract Documents for the Project entitled: **CITY OF HIALEAH – PALM CENTER PARKING GARAGE – STRUCTURAL PILES, BID NO. 2009/10-3230-00-085** is amended as noted in this Addendum No. 2.

This Addendum No. 2 consists of 1 Typed Page, 0 Sketches 1 Attachment and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue: _____



Date: June 18, 2010

Oniel E. Toledo – Capital Project Manager
Construction & Maintenance

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 2** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah @ (305) 687-2642 and submitted with sealed bids.

ATTACHMENTS:

ATT-1 E-MAIL FROM: BERKEL & COMPANY CONTRACTORS (dated 06/18/2010)

ANSWER TO: BERKEL & COMPANY CONTRACTORS - e-mail dated 06-18-10

1. Contractor must provide one (1) compaction test and one (1) tension test. The City of Hialeah will provide the testing company that will monitor the pile load test.

STRUCTURAL PILES, BID NO. 2009/10-3230-00-085

**PAGE 1 OF 1
END OF ADDENDUM No. 2**

ADDENDUM RECEIPT FORM

**CITY OF HIALEAH
PALM CENTER PARKING GARAGE
STRUCTURAL PILES**

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____ **FAX NO.** _____

CONTACT NAME _____ **SIGNATURE** _____

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY OF HIALEAH @ (305) 687-2642

ADDENDUM

SIGNATURE

DATE

2

ARF

Toledo, Oniel

From: Stacey Rock [srock@berkelapg.com]
Sent: Friday, June 18, 2010 9:42 AM
To: CLopez@hialeahfl.gov
Cc: Toledo, Oniel
Subject: Milander / Palm Center

Hello Carlos:

Good Morning – I have a question on both projects, if you could please review send answer as soon as possible...

(RE: **MILANDER**) On the summary of work contained in Addendum No. 1, Item # 4, regarding test piles: Please confirm the type and quantity of test piles required. Please note that per the Florida Building Code a 35 ton design load does not require a test pile.

(RE: **PALM CENTER**) On the summary of work contained in Addendum No. 1, Item # 4, regarding test piles: Please confirm the type and quantity of test piles required.

Please call if you have any questions.

*Thank You,
Stacey Rock
Administration - SF Office*

*Berkel & Company Contractors, Inc.
3702 Rogers Industrial Park Road
Okahumpka, FL. 34762*

*Ph: 352-365-4308
Fax: 352-365-4360
Email: srock@berkelapg.com*



ATT-1

6/18/2010