

ADDENDUM NO. 3

CITY OF HIALEAH


**ROADWAY IMPROVEMENTS WEST 18TH AVENUE
FROM WEST 60TH STREET TO NORTH OF WEST 64TH STREET
2008/09-3210-00-060**

September 10, 2009

TO ALL CONCERNED

The original Contract Documents, for the Project entitled CITY OF HIALEAH – ROADWAY IMPROVEMENTS WEST 18TH AVENUE FROM WEST 60TH STREET TO NORTH OF WEST 64TH STREET, are hereby amended as noted in this Addendum No. 3.

This Addendum No. 3 consists of 2 Typed Pages. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: September 10, 2009
Michael Flores – Purchasing Director

ACKNOWLEDGEMENT

Receipt of this Addendum No. 3 shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah at (305) 883-5871 and submitted with sealed bids.

Questions and Answers:

- Q1. Can you verify for me if a registered Vendor for Miami Dade County status, satisfies the Dade County Certificate of Competency & Occupational License requirements for the aforementioned project. Should this not be the case, can you please direct me to the correct path to achieving these requirements. (This is listed under 'Bidders Qualifications' for the 'City of Hialeah ' West 18th Ave., from West 60th St. to N of West 64th St.' Project, page 17, 2nd paragraph).
- A1. You can either have a Miami-Dade County Certificate of Competency or an active state license showing the requisite calculations to do the job.
- Q2. We can't seem to find any demolition plans or notes and are wondering if we should demolish all existing items found in typical section, shown on sheet 2, and labeled as "standard clearing and grubbing." That is to assume all exiting asphalt, driveways, sidewalks, curbing, pavers, and base courses (limerock material) to be removed completely. This is the reason why we are sending this RFI to verify and confirm if this is a good assumption or only a fraction of these items to be removed? Please advice? Not only that but what about any existing drainage or infrastructures, that are to be removed or abandon as well? Also, is the regular excavation item (4393 CY) is this limerock or subgrade material or both that is to be removed from under the existing asphalt?
- A2. The plans call for closing the entire street in two phases. Contractor can demolish the existing sections as call in the plans.
- Q3. Is the thickness of demucking that we need to removed, is not shown any where?
- A3. We are not demucking, sheet 3 calls for geogrid under the base for the muck areas.

ADDENDUM RECEIPT FORM

CITY OF HIALEAH

ROADWAY IMPROVEMENTS WEST 18TH AVENUE
FROM WEST 60TH STREET TO NORTH OF WEST 64TH STREET
2008/09-3210-00-060

September 10, 2009

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____ FAX NO. _____

CONTACT NAME _____ SIGNATURE _____

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY of HIALEAH @ (305) 883-5871

<u>ADDENDUM</u>	<u>SIGNATURE</u>	<u>DATE</u>
3	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____